



Product Alert - Misrepresentation of FM Approved Product

March 8, 2021

Type of Notification: Misrepresentation of FM Approved Product

FM Approvals has been made aware of an issue where the FM Approvals certification mark was inadvertently applied to Smith-Cooper International, Model No 65E-HP grooved pipe fittings. None of these pipe fittings are FM Approved as they have not been tested or examined by FM Approvals.

Company Identity: Anvil International, LLC

Address: 2 Holland Way, Exeter, New Hampshire 03833, USA

Contact Information: Compliance Department (Compliance@anvilintl.com)

Product Identity: Smith-Cooper International, 65E-HP

Description: High Pressure Pipe Fitting

FM Approval Status: Not FM Approved

Hazard Involved:

Smith-Cooper International, models 65E-HP have never been tested or certified by FM Approvals. Use of products that falsely claim FM Approval may present a property risk for the end user.

If you suspect you are in possession of a Smith-Cooper International, Model 65E-HP High Pressure Pipe Fittings bearing the FM Approvals certification marking and require assistance, please bring that to the attention of:

Antonio L. Pires
FM Approvals, Quality Department
Norwood, MA, USA
+1 (1)781 255 4825
Email: antonio.pires@fmapprovals.com